


Cable Particulars for the Thermotank Circuits:-

No.	BHP	No.per Pole.	No.& Diam. of Strands.	Max. Current. Circuit.	Rule.	Approx. Length.	Insul.	Protection.
1K	1	1.5	1	7.036	13.5	24	100	VIR. L.C.
2K	1	1.5	1	7.036	13.5	24	100	" "
3K	1	1.5	1	7.036	13.5	24	80	" "
4K	1	2.5.	1	7.036	22.5	24	120	" "
5K	1	2.5	1	7.036	22.5	24	100	" "
6K	1	2.5	1	7.036	22.5	24	80	" "
1J	1	2.5	1	7.036	22.5	24	90	" "
2J	1	2.5	1	7.036	22.5	24	40	" "
3J	1	2.5.	1	7.036	22.5	24	75	" "
4J	1	2.5	1	7.036	22.5	24	110	" "



© 2020

Lloyd's Register
Foundation

002876-002820230