

ENCLOSURE.

16th April, 1948.

M.S. "SOMMER". (R.M.C.)

Dear Sir,

I have to acquaint you that the refrigerating appliances of the above named vessel were constructed under the supervision of the American Bureau in 1945. Classification with this Society is now desired, however, and the Helsingborg Surveyors report they have examined this installation for classification and recommend notation of Lloyd's R.M.C. 3.48 ) for temp -5°F.  
S.R.M.C. 3.48 )  
when the survey has been completed. To complete the survey the cooling down tests requires to be carried out and this, it is stated, will be done at an East American port about May 1948. I shall be glad if you will arrange accordingly.

The capacity of the refrigerating<sup>machinery and</sup> appliances, calculated from the information in the report and plans and in the general Electric Co's brochure, appears to be adequate for the installation and the type and thickness of insulation is satisfactory. The ice melting capacity in tons per 24 hours is calculated to be about 13. There appears to be no access to the air circulating fans and motors, but the cooling grids in the refrigerated spaces are considered to be sufficient for maintaining the temperature independent of the air cooling units.

I enclose a photographic copy of the Helsingborg Surveyors' first entry report and I shall be glad if you will draw the Surveyors' special attention to the specified temperature, viz. -5°F., when the cooling down test is being carried out.

Yours faithfully,

Clerk to the  
Classification Committee.

The Principal Surveyor,

NEW YORK.



© 2021

Lloyd's Register  
Foundation

003409-003416-0078