

GLASGOW,

25th August, 1923.

H.C. FORSTER

Messrs. Cochran & Co. Annan Ltd., examine the Donkey Boiler No. 8921 made by them to the order of Messrs. David Rowan & Co. Ltd., Glasgow, for their Contract No. 760.

The scantlings of the Boiler were found to be in accordance with the Rules of Lloyd's Register for a working pressure of 100 lbs per square inch. The steel material used in the construction of the Boiler was tested by the Society's Surveyors in accordance with the Rules, and the workmanship so far as seen was good.

The Boiler was tested by hydraulic pressure to 200 lbs per square inch in the presence of the undersigned Surveyor and was found sound and tight at that pressure.


Working pressure not to exceed One Hundred Pounds per square inch.

Marks on Boiler No. 8921.

No. 16322
LLOYD'S TEST
200 lbs.
W.P. 100 lbs
H.C.F. 24.8.23.

H.C. Forster

Surveyor to Lloyd's Register.



Lloyd's Register
Foundation

008917-08924-0034