

# COPY

[2 JUN 1930

## Lloyd's Register of Shipping,

Port NAGASAKI.

26th June, 1929.

CERTIFICATE No.154.

This is to Certify that

K. Kishigami.

the undersigned Surveyor to this Society did at the request of Messrs. Mitsubishi Denki Kaisha, Ltd., attend at their works at Nagasaki on the 18th June 1929, in order to examine under test one Compound wound, direct current, 35 K.W. Generator, No.12418, of 225 volts, by 155 amps and 1800 revolutions per minute, for Emergency Generator.

This generator ordered by Messrs. Ikogai Tekko-sho., Tokio, is intended for Vessel No.177, now being built by Messrs. Yokohama Dock, Co., YOKOHAMA.

The generator was submitted to the following tests:-

- Full load test of 6 hours duration.
- 25% overload test of 2 hours duration.
- 50% overload test for 3 minutes.

The rise of temperature was measured by thermometers and on completion of trials high voltage (2000 volts A.C.) and insulation tests were carried out, and all found satisfactory.

For purposes of identification the generator has been stamped on the casing as follows:-

LLOYD'S  
No.154. *KK*  
K.K.18-6-29.

*K. Kishigami*  
*assid. Surveyor to Lloyd's Register*

This Certificate is issued upon the terms of the Rules and Regulations of the Society, which provide that:

"While the Committee use their best endeavours to ensure that the functions of the Society are properly executed, it is to be understood that neither the Committee nor the Society are under any circumstances whatever to be held responsible for any inaccuracy in any report or certificate issued by the Society or its Surveyors, or in any entry in the Register Book or other publication of the Society, or for any error of judgment, default, or negligence of the Surveyors, or other Officers or Agents of the Society."

(Rpt. ro.)

010369 - 010377 - 0034

26/3  
157

© 2021

Lloyd's Register  
Foundation