

Shipbuilders: Messrs. 'Brasil'

Yard No.

Engineers: Messrs.

Engine No.

Genoa Surveyor's Letter dated 21st April, 1951

It is submitted the Plans enclosed with the above letter
require approval provided the engs. be as shown on the
plans & the remaining requirements of the Rules for Refrig.
A/C & Appliances be complied with so far as they are applicable.

That the Surveyors be informed that the contents of
the Data Sheet & their letter have been noted & with
reference to the former it be pointed out the total ^{external} exposed
surface of insulating envelope ^{should} include all boundaries ^{should} of
the refrigerated spaces, & similarly the deck edges exposed
to external conditions ^{should} include all those which lead outside
the refrigerated space, whether to atmosphere, other cargo spaces,
machinery spaces, or hatch trunks etc.

That with further reference to the Data Sheet, the
external tube surfaces of the Freon Condensers & Evaporators
appear to be very small, & a sketch of these components
showing the number, length & diameter of the tubes in
each should be forwarded.

That the Surveyors be advised the Survey for
Classification should be in accordance with Sect. 5 of
the Rules, & that it is ~~considered~~ essential owing to the
age of this installation it is considered essential that
the Condensers & Evaporators should be tested as laid
down in Sect. 6, clauses 8(b) & (c).

turn 2 plan. copies 1 plans

tain 1 copy. 2 "

L.9.49.

