


Lloyd's Register of Shipping.



Exp.:	19. APR. 1950
Countw.:	

Port Bremerhaven,

15th April, 1950.

This is to Certify that

J.P. Gateley

the undersigned Surveyor to this Society did at the request of

the Lloyd Dynamo Werke, Bremen, attend their works on 14th April, 1950, for the purpose of witnessing tests on two (2) D.C. Compound Wound 100 KW Generators, made to the order of Allgemeine Elektrizitätsgesellschaft Shipbuilding, Hamburg.

Machine Nos. 610629/30,
 Works Nos. 92684/5,
 Type AW 115 Mod.
 100 KW,
 230 Volts,
 435 Amps.,
 480 RPM.

The following tests were applied and the generators were in accordance with the specification: -

- Overload 650 Amps., 2 mins.
- Overspeed 580 R.P.M., 2 mins.
- Armature test 300 Volts, 3 mins.
- Dielectric 2000 Volts, 1 min. & 1000 Volts 1 min.
- Insulation 10 meg.ohms.

Shafts were stamped to Lloyd's Test as follows: -

2969, 4740, LR 196, LLOYD'S 6680/81, 8.3.50, J.P.G., 14-4-50.

The above tests being satisfactory, insulation material to Class A requirements, the frame was stamped for purposes of identification

LLOYD'S TEST,
 J.P.G.,
 92684/5,
 14-4-50.

MER
 KAN
 36

This Certificate is issued upon the terms of the Rules and Regulations of the Society, which provide that:—
 While the Committees of the Society use their best endeavours to ensure that the functions of the Society are properly performed, it is to be understood that neither the Society nor any Member of any of its Committees is under any circumstances to be held responsible for any inaccuracy in any report or certificate issued by the Society or its Surveyors, or in any entry in the Register Book or other publication of the Society, or for any error of judgment, default or negligence of any of its Committees or any Member thereof, or the Surveyors, or other Officers or Agents of the Society."

002515-002521-0242

THU 3 MAY 1951