

COPY

LLOYD'S REGISTER OF SHIPPING

UNITED WITH THE BRITISH CORPORATION REGISTER

Port Copenhagen

29th August, 1956.

CPN. 1ST ENTRY REPORT NO. 16121.

This is to Certify that

M. Nielsen

the undersigned Surveyor to this Society did at the request of

Messrs. Motorfabriken Bukh, Kalundborg

Copenhagen, attend their works for the purpose of examining the
undermentioned pump.

The pump examined and tested in my presence by hydraulic pressure and
found sound and tight.

Running test carried out with satisfactory result.

Description of pump:- Centrifugal pump
intended as: fire pump
for Messrs. Bukh, Kalundborg, their stock
Yard No.:

Pump No. 5348 ✓
Type Desmi C-3-50/65

Diameter of cylinder - mm

Stroke - mm

Revolutions per minute 2940

Capacity - m³/hour 25

Head - meter 70

Discharge pressure kg/cm² 7

Test pressure Atm. 14

Date of survey:- 28-8-56.

Mark for identification:-

Lloyd's Test CPN Atm. 14

MN 28-8-56.

Fee ~~and Exp.~~ Kr. 50,00

Certificate is issued upon the terms of the Rules and Regulations of the Society, which provide that:-
While the Committees of the Society use their best endeavours to ensure that the functions of the Society are properly
performed, it is to be understood that neither the Society nor any Member of any of its Committees is under any circumstances
to be held responsible for any inaccuracy in any report or certificate issued by the Society or its Surveyors, or in any
entry in the Register Book or other publication of the Society, or for any error of judgment, default or negligence of any of
its Committees or any Member thereof, or the Surveyors, or other Officers or Agents of the Society.