

NAME ..... M/V - THYRA TORM ..... Rpt Nos. .... CPN 16882  
ABG 16882

This vessel's refrigerating machinery has been built and installed under Special Survey in accordance with approved plans and Rule requirements.

All necessary tests have been satisfactorily carried out.

IT IS SUBMITTED this refrigerating installation merits approval, with record of:-

+ LLOYDS RMC 3/58  
+

" to maintain temp. 5°F. with cooling. 86°F maximum."

CERTIFICATE WRITTEN.

EW

25/4/58



© 2021

Lloyd's Register  
Foundation

003567-003571-0052