

Thomas B. Thrige

Odense

BELONGS TO AMSTERDAM REPORT
No. 10719

TEST-SHEET

A/S Elektrisk Bureau, Oslo.

0392 1951

/11-51

enclosed ventilated

10x20

Armature No.:

C 33822

2

Brushes No. K10

Quality:

D450

compound motor

Type

HLJ 5b

No.:

2010035

Volts:

110

Amps:

13,7

R. P. M.:

1450

HP. / kW:

1,5

Rating:

cont.

test voltage: 1500 volts for 1 min. Resistance: megohms.

Terminal Volts	Line Amps.	Shunt		R. P. M.	Air. temp. °C.	Remarks
		Volts	Amps.			
110	13,7			1340	23,0	
"	"			1350		
110	13,7			1350		
"	"			1360		
"	1,12	110	0,45	2240		

Temperature rise:

Armature:

°C, Shunt:

°C,

Series-winding:

°C, Interpoles:

°C, Commutator:

°C

5/5 "SIREDAL"
electric motor of F.O. burning pump

Manufactured and tested in accordance with

Odense, Denmark

29/1-53

pr. Thomas B. Thrige

© 2020

Lloyd's Register
Foundation

003605-003610-0158