

CAMPBELL & ISHERWOOD LTD.

BOOTLE, LIVERPOOL.

21645.

2201.G.

5-12-43.

CERTIFICATE OF TEST.

C.&I. 1350/1000 SIZE DRIP PROOF TYPE, DOUBLE BEARING, FAN VENTILATED, COMPOUND WOUND GENERATOR.

- 40 kw. 220 volts 182 amps. 800 rpm.

<u>VOLTS</u>	<u>AMPS.</u>	<u>SHUNT AMPS.</u>	<u>R.P.M.</u>
258	0	2.28	800 Full Field.
209	0	1.35	800
220	182	1.4	800
220	182	1.38	800
220	182	1.38	800
220	182	1.38	800
220	182	1.38	800
220	182	1.38	800
220	182	1.38	800
220	182	1.38	800
220	182	1.38	800
220	182	1.38	800
220	182	1.38	800
220	182	1.38	800
220	182	1.38	800
220	182	1.38	800) Hot Final
209	0	1.26	800) Comp.
253	0	2.05	800 Full Field. No. Load.
260	182	2.1	800 Full Field. On Load.
198	182	1.0	800 10% Down. 72 volts on Reg.

here	58°F	Rise
re Windings.	98°F	40°
re Core	98°F	40°
	80°F	22°
	81°F	23°
ole	81°F	23°
	83°F	25°

220	227	1.3	800)	
220	227	1.3	800)	25%
220	227	1.3	800)	
220	227	1.3	800)	Overload.
220	227	1.3	800)	for two hours.

ION RESISTANCE HOT:- 16 MEGS.

TESTED AT 2000 VOLTS.

© 2020

CAMPBELL & ISHERWOOD LTD.

Lloyd's Register
WOOD LTD.,
Foundation

003706-003711-0045