

COPY

Lloyd's Register of Shipping.

Port NAGASAKI.

4th October 1933.

CERTIFICATE No. 791.

This is to Certify that

at the request of Messrs. Mitsubishi Denki Kaisha Ltd., attend at their works at Nagasaki, on the 25th September 1933 & subsequent dates, in order to examine under test, Three compound wound, direct current, 90 K.W. Generators, No. 14341, 14342 & 14343, of 225 volts, by 400 amps at 400 revolutions per minute.

These Generators ordered by Messrs. Mitsubishi Zosen Kaisha, Ltd., Nagasaki, are intended for Vessel No. 552, now being built by them.

The Generators were submitted to the following tests:-

Full load test of 5 hours duration.
25% overload test of 2 hours duration.
50% overload test for one minute.

The rise of temperature was measured by thermometers and on completion of trials, high voltage (2000 volts, A.C.) and insulation tests were carried out, and all found satisfactory.

For purposes of identification the Generators have been stamped on the casings as follows:-

<u>Gen.No.14341.</u>	<u>Gen.No.14342.</u>	<u>Gen.No.14343.</u>
LLOYD'S	LLOYD'S	LLOYD'S
No.791. <i>R</i>	No.791-A. <i>R</i>	No.791-B. <i>R</i>
<u>HDB 25-9-33.</u>	<u>BZ 22-9-33</u>	<u>FR 27-9-33.</u>

H. Buchanan
SURVEYOR TO LLOYD'S REGISTER.

This Certificate is issued upon the terms of the Rules and Regulations of the Society, which provide that:-

"While the Committee use their best endeavours to ensure that the functions of the Society are properly executed, it is to be understood that neither the committee nor the Society are under any circumstances whatever to be held responsible for any inaccuracy in any report or certificate issued by the Society or its Surveyors, or in any entry in the Register Book or other publication of the Society or for any error of judgment, default, or negligence of the Surveyors, or other Officers or Agents of the Society.