

COPY.

Lloyd's Register of Shipping.



Port NOTTINGHAM. 17th December, 1943.

CP. 95/93730/42/K. 6884 (R. in C.)

International Combustion Ltd. Boiler No. 340/37/5

C. 2062

This is to Certify that

~~the undersigned Surveyor to this Society did at the request of~~

The water tube Boiler No. 340/37/5 made by The International Combustion Ltd., at Derby and marked as below, has been surveyed during construction by the undersigned.

The material has been tested by the Society's Surveyors as required by the Rules; the scantlings are in accordance with the plans approved for a working pressure of 225 lb. per square inch and the workmanship is good. The boiler has been tested in my presence on the 4th November, 1943, by hydraulic pressure to 387 lbs. per square inch, and was found tight and sound in every respect at that pressure.

MARK ON BOILER

No. 36
Lloyd's Test
387 lbs.
W.P. 225 lbs.
4.11.43. AWJ.

A. W. Jones.

ENGINEER SURVEYOR TO LLOYD'S REGISTER.

This Certificate is issued upon the terms of the Rules and Regulations of the Society, which provide that:—
“While the Committees of the Society use their best endeavours to ensure that the functions of the Society are properly executed, it is to be understood that neither the Society nor any Member of any of its Committees is under any circumstances whatever to be held responsible for any inaccuracy in any report or certificate issued by the Society or its Surveyors, or in any entry in the Register Book or other publication of the Society, or for any error of judgment, default or negligence of any of its Committees or any Member thereof, or the Surveyors, or other Officers or Agents of the Society.”