

COPY. *Japan*

Lloyd's Register of Shipping.

Port of BREMEN

27th September 1926.

This is to Certify that

P. A. Krützfeldt

the undersigned Surveyor to this Society did at the request of Messrs. Siemens-Schuckertwerke G.m.b.H. try and examine on the 21st September 1926 at their works at Nürnberg a compound wound direct current Generator, No. 1825.576, Type GV 340 of 225 Volts by 367 Amperes rating and 350 revolutions per minute. This Generator has been ordered for the M.V. No.427 of Messrs. Mitsubishi Zosen Kaisha of Nagasaki.

In the presence of the undersigned the generator has been submitted to a trial under full working condition of four hours duration at rated full load. During and on completion of the trial the temperatures were measured at various spots by means of thermometers and the rise of temperature was found to reach in no case 35° C. The generator is over-compounded 5 % under conditions of constant speed and excitation. On completion the insulation has been tested and was found in order.

For identification the generator has been stamped:-

LLOYD'S

339

P.K. 21.9.26.

sgd. P.A. Krützfeldt.

This Certificate is issued upon the terms of the Rules and Regulations of the Society, which provide that:—
“While the Committee use their best endeavours to ensure that the functions of the Society are properly executed, it is understood that neither the Committee nor the Society are under any circumstances whatever to be held responsible for accuracy in any report or certificate issued by the Society or its Surveyors, or in any entry in the Register Book or other publication of the Society, or for any error of judgment, default, or negligence of the Surveyors, or other Officers or Agents of the Society.”