

examined and found in good condition

Main Generator rotor and stator windings, cleaned and coated. Rotating field re-
to General Electric Co. shop, overhauled. Dynamically balanced High
test of 1440 volts applied for one minute duration. Rugs tested and replaced
Trust and Thrust shaft, bearings, thrust collar and shoes, examined and found
intermediate line shafting and bearings, examined.
Pumps, piping and pumping arrangements examined and found in good condition

- The following parts of Auxiliary Machinery opened and examined throughout
- Main and Auxiliary Condensers found clean, tested and water tests passed
- Main & Auxiliary Circulating pumps, together with Electric Motors
- Two (2) Turbo driven centrifugal feed pumps 1st side shaft recess.
- Auxiliary Reciprocating steam driven feed pump 1st side tower E.R.
- Atmospheric Drain Reverse pump (centrifugal) together with Electric Motor
- Two (2) Lubricating oil service pumps, together with Electric Motors 1st side
- Two (2) Fuel oil transfer pumps, Inboard & Outboard with Electric Motors 1st side
- Two (2) Fuel Oil service pumps, forward and aft with Electric Motors 1st side
- Two (2) Evaporator feed pumps, forward and aft with Electric Motors Port side
- Two (2) Fresh water pumps Inboard & Outboard with Electric Motors Port side
- Two (2) Main Condensate pumps, Port & 1st side with Electric Motors Port side
- Auxiliary Condensate pump with Electric Motor 1st side tower E.R.
- Fire and Buterworth pump with Electric Motor Port side shaft recess.
- Fire and Buterworth pump with Electric Motor Port side tower E.R.
- Engine room Bilge pump with Electric Motor Port side tower E.R.
- Engine room Bilge pump with Electric Motor Port side shaft recess.
- Portable Drinking water pump with Electric Motor 1st side Boiler room
- Fresh water pump with Electric Motor Weather deck midship
- Fuel oil transfer pump, Steam driven forward pump room.
- Bilge & Ballast pump Steam driven forward pump room
- Salt water service pump with Electric Motor Port side shaft recess.
- Sanitary pump with Electric Motor Port side shaft recess.
- Port & 1st side Main Cargo pumps with Electric Motors. Motors in Eng
pumps in after pump room
- Port & 1st side Striping pumps with Electric Motors. Motors in Engine room
- Pumps in after pump room
- Cargo Striping pump, Steam driven, after pump room
- Two (2) Evaporators, Port side upper E.R. aft. Spind cleaned coils & shell tested, caps
adjusted.
- Two (2) Lubricating oil coolers, aft upper E.R. Spind cleaned and tested
- Two (2) Fuel oil heaters, port side boiler room fwd end.
- Fwd water heater (Tray type) cleaned and tested. Off end Boiler
- Main & Auxiliary Air Exhausters port side aft E.R. Spind and examined
- Inboard & Outboard Auxiliary generators & Turbines. Reduction gear, governor gear, etc.
- Lubricating oil storage tanks upper E.R. 1st side Spind cleaned examined and tested.
- The 2 Main H.T. Boilers were examined over all parts, with doors mounting and
valves & found in good condition. Safety valves adjusted under 110
to W.P. 500 lbs. Superheater safety valve adjusted to 485 lbs.
- Fuel oil burning system with installation of pumps, piping, valves, and deck control
examined under working conditions and found in good condition

Machinery repairs

Main turbine. All interstage diaphragm lathe packing removed, cleaned and
internal surfaces of turbine casings and valve were wire brushed and cleaned
bearings and thrust adjusted. overspeed governor spind cleaned and placed in
Inboard and Outboard Auxiliary Turbos. Generator. Turbine & reduction casings
casings, rotor Hadding, wire brushed, diaphragm packing port renewed. gland seal
bearing row renewed. Lubricating oil piping removed and cleaned and replaced

Main circulating pump, remounted bearings, spare impeller & shaft fitted. original shaft
removed and placed on hand as spare.
Main feed pump, Inboard Turbine casing opened & examined. Pump casing, gland and
impeller redesigned, ground gear overhauled. tried out with overspeed, and found in order.
Main feed pump aft Turbine casing opened & examined. Pump casing, gland
seal rings renewed, thrust shoes renewed. tried out and found in good order.
Auxiliary feed pump, liquid end, rings renewed, section & delivery valves. Inboard
fresh water pumps inboard impeller shaft renewed.
Main Condensate pump, impeller shaft steams renewed.
Engine room Bilge pump, lines & valves renewed. Port side E.R.
Fire & Buterworth pump port side shaft recess valves renewed.
Cargo Striping pump forward pump room. Liquid end lines renewed, hanger packing
renewed section & delivery valves renewed.

Boiler repairs including superheater safety valves
Safety valves removed to General Electric shop, thoroughly overhauled and replaced in
good order. Superheater drain valves renewed port boiler.
A number of hand hole plate on Port boiler removed for examination of tubes
Broken on Port superheater doors renewed.
Broken in Port boiler repaired as necessary. Those in talk rollers renewed.
Hydrostatic pressure of 525 lbs applied to talk valves and found tight.

Electrical repairs
Main circulating pump motor armature removed to shop.
Dynamically balanced and replaced in good condition.
Main motor reversing switch contact tips renewed.
Crate, placed through motor bearings renewed. All screws throughout the vessel replaced
with non-ferrous type with refractory filler. Deck outlets replaced with Smith interlocked outlets.
Pump room fixtures, brassing glass shade and gaskets renewed in forward and after pump rooms.
Talkring conductor on signal mast installed.
Generators, Inboard & Outboard, tested under full load. Governors tested by throwing
the full load on and off. Collector ring on talk generators stored and brushes refitted.
Auxiliary generator windings cleaned and coated.

Cargo pump control, valve cleaned, driven and adjusted.
Impeller for Sea Exhausters removed to General Electric shop, thoroughly
overhauled and replaced in good condition.
1st side Main Cargo pump motor after full end motor frame being fractured
removed and bronze welded attachments checked in place. Replaced in good condition.
The electrical installation examined under working conditions, generator cables, fittings on
the main switchboard and in distribution boxes examined.
Insulation resistance tests made on all circuits, minor repairs effected all found to be
in good order.

The following valves cleaned, overhauled and found in good condition
3 Main Cargo and 2 Striping pump valves. Forward Evaporator pump motor.
After Fire & Buterworth pump motor. Port & 1st side Steering gear motor.
Emergency generator & Diesel engine tried out under working condition and
found satisfactory. All machinery seen under working conditions during port
and sea trials and found satisfactory.

27510

