

LLOYD'S REGISTER OF SHIPPING

PORT MANILA, P. I.

30th June, 1939.

THIS IS TO CERTIFY that

----- C. B. NELSON, -----
the undersigned Surveyor to this Society did at the request of
MESSRS. MENZI & COMPANY, INC., attend on 24th June, 1939,
at the EARNSHAW'S DOCK & HONOLULU IRON WORKS, for the pur-
pose of testing and inspecting the Fire Extinguishing Pump
for the M/V "MAMBUKAL" as specified below to the order of
MESSRS. C. ANDRE & CO., HAMBURG.

S P E C I F I C A T I O N S

Makers Type -----	ENF 60 e
Makers No. -----	860 760
Speed -----	2100 r.p.m.
Total Manometric head -----	40 m
Output -----	5,55 Ltr/Sec.
H.P. Required -----	8
Motor capacity -----	10 H.P.

The Pump has been submitted to a trial with the
following results:

R.P.M.	Total Manom.height lbs. per sq. in.	Output Cu.Ft.per min.	H.P.
2000	61,00	9,50	10,00
2000	60,00	12,10	9,20
2100	75,00	0	10,23

For identification the Pump has been stamped after
completion of the trial.

LLOYD'S
ERS
MANILA
6-24-39

Fee as per account.

(Sgd.) E. R. SANDERSON
For C. B. NELSON
SURVEYOR TO LLOYD'S REGISTER

This Certificate is issued upon the terms of the Rules
and Regulations of the Society.



© 2021

Lloyd's Register
Foundation

W103-0014