

## Lloyd's Register of Shipping.



COPY.

Collingwood Buildings,  
Newcastle-on-Tyne, 1, 11th October, 1934.

This is to Certify that  
the undersigned Surveyor to this Society did at the request of  
The North Eastern Marine Engineering Co. Ltd.,  
attend their works on the 8th October, 1934, for the purpose of  
inspecting 4 Steam Superheater Headers designated S.H.505,  
Test No. - - -  
made to the order of Messrs. Amos & Smith,  
and intended for their C. No. 639.

The ~~cast~~ wrought steel headers in question were mechanically tested in  
accordance with the Rules of this Society. ~~A copy of the results of  
these tests is appended.~~

The headers were, in the presence of the undersigned, tested by  
hydraulic pressure to 630 pounds per square inch and found satisfactory.

The headers are, so far as can be seen, sound and free from  
defects, and are suitable for a working pressure of 210 pounds per  
square inch.

10% of the Elements tested to 1,500 lbs. per square inch and  
found satisfactory.

Identification Mark:—

No. S.H.505
LLOYD'S TEST.
630 lbs.
Working Pressure 210 lbs.
H.C.F. 8-10-34.

(Signed) H. C. Forster.

Engineer Surveyor to Lloyd's Register.

NEWCASTLE ON TYNE.

Fee :- £1.6.8

© 2000

COPY.

This Certificate is issued upon the terms of the Rules and Regulations of the Society, which provide that:

"While the Committee use their best endeavours to ensure that the functions of the Society are properly executed, it is to be understood that neither the Committee nor the Society are under any circumstances whatever to be held responsible for any inaccuracy in any report or certificate issued by the Society or its Surveyors, or in any entry in the Register Book or other publication of the Society, or for any error of judgment, default, or negligence of the Committee or any Member thereof, or the Surveyors, or other Officers or Agents of the Society."