

HORIZONTAL FLUE TUBES.



HEATING SURFACE	
TUBES	647 Sq.Ft.
PLATE	103 Sq.Ft.
TOTAL	750 Sq.Ft.
GRATE AREA	31.5 Sq.Ft.

RETAIN

Cochrane & Co. Annanhd

Boiler N° 9088

W.P. 100 lbs/12"

Mark'm Boiler N° 9088

N° 16281

LLOYD'S TEST

200 LBS.

W.P. 100 LBS.

H.C.F. 15.6.23

GLASGOW REPORT N°.

42832



© 2020

Lloyd's Register
Foundation

W1220-0242