

BOAT DECK

BRIDGE DECK

UPPER DECK

LONDON COPY.

FIRE EXTINGUISHING VALVE
CONTROLLED FROM BOAT DECK

71 74 77 80 85 86 89 92 93

GENERAL SERVICE PUMP

EXISTING HOSE 50'-0" LONG
FITTED ON DELIVERY OF GENERAL SERVICE PUMP

EXISTING WATER SERVICE
COCK

1" PERFORATED PIPE
HOLES 3" SPACED

AUXIL^y STEAM PIPE FROM
THE 3 BOILERS

OBSERV
TANK

DUPLEX PUMPING &
HEATING UNIT

TRANS
PER PUMP

SETTLING TANK

SETTLING TANK

1" PERFORATED PIPE HOLES
3" SPACED

HOSE 30'-0" LONG
CONNECTED ON WATER SERVICE COCK

EXISTING WATER SERVICE COCK

The flash point of the oil fuel to be above 150°F, and
the remaining requirements of Section 20 of P. R. 1's
1938-9 to be complied with on fire rule

LONDON COPY.

S/S HELMSPEY

FIRE EXTINGUISHING ARRANGEMENT
IN ENGINE & BOILER SPACE

Scale 1/4" = 1'-0" FL 2586 883

MERCANTILE MARINE ENGINEERING & G.D.C. ART. 2-6-39

W176-0039