

For Glasgow.

COPY.

C.9424

Lloyd's Register of Shipping.

GLASGOW REPORT No 58862

Port LONDON,

15th March, 1937.



This is to Certify that

H. N. PEMBERTON,

the undersigned Surveyor to this Society did at the request of Messrs. Dewrance & Co., attend at their works at Great Dover Street, London, S.E., on the 2nd March, 1937, for the purpose of testing two sets of water gauges and two water level indicators intended for Messrs. Babcock & Wilcox. (Order Nos. 34/1320 and 34/1321).

The fittings were examined and subjected to an hydraulic test pressure of 500 lb. per square inch with satisfactory results.

For identification purposes each fitting was stamped:-

C.9424
LLOYD'S TEST 500 lb.

HAP


Fee:- £1.1.0

Surveyor to Lloyd's Register of Shipping,

To Submit

This Certificate is issued upon the terms of the Rules and Regulations of the Society, which provide that:-

"While the Committees of the Society use their best endeavours to ensure that the functions of the Society are properly executed, it is to be understood that neither the Society nor any Member of any of its Committees is under any circumstances whatever to be held responsible for any inaccuracy in any report or certificate issued by the Society or its Surveyors, or in any entry in the Register Book or other publication of the Society, or for any error of judgment, default or negligence of any of its Committees or any Member thereof, or the Surveyors, or other Officers or Agents of the Society."



© 2019

Lloyd's Register Foundation

W180-0249