



NOTE: ALL CASING JOINTS SEALED WITH  
J M AERTITE CEMENT

SOOT BLOWERS ON BOTH SIDES OF BOILER

12 - 1-1/2" G-9-B UNITS PER BOILER

A & B DIALOY UNITS  
C CALORIZED UNIT  
D, E & F PLAIN UNITS

- A TO F - SOOT BLOWER UNITS  
G - FIREBACKING BLOCK  
H - 2-1/2" ARMSTRONG INSULATING BLOCKS  
I - ASBESTOS CEMENT  
J - 12" x 16" MANHOLE  
K - ACCESS DOOR IN BOTH SIDES  
L - 1/4" ASBESTOS  
M - MOULDABLE FIREBRICK  
N - 2" FIREBACKING  
O - STRAIGHT FIREBRICK #80  
P - SPLIT FIREBRICK #80  
R - ACCESS DOOR IN ONE SIDE OF BOILER  
S - BRICK UP LOOSE  
T - 1" FIREBACKING

RETURN TO LIBRARY ST  
MB-1130

FOR FRONT VIEW SEE MI-192170

THIS DRAWING, OWNED BY  
THE BABCOCK & WILCOX COMPANY  
IS CONDITIONALLY LOANED TO

WHO BY RECEIVING IT HAS AGREED NOT TO REPRODUCE OR  
ON COPY IN WHOLE OR IN PART OR TO FURNISH IN-  
FORMATION FROM IT TO OTHERS, OR TO MAKE ANY USE  
OF IT THAT IS OR MAY BE INJURIOUS TO THE BABCOCK  
& WILCOX COMPANY, AND TO RETURN IT UPON REQUEST

LONGITUDINAL SECTION

SCALE 3/4"	DATE 2/27/29
SHEET 42	DRAWER JGS
MI-192169-K	2 M.B. 1130-1131

EJR

32 6(4-2)  
42 2-1/2(4-2) 11'0" OLS  
1-4" TS

PRINTED FOR FILE:- (1) Corrected dimension for location of Soot Blower 4/25/29. (2) Altered dimension locating element "B" from 3'5" to 3'2" 5/22/29

W313-0126

S/S BULK OIL  
NEWPORT NEWS RPT 5002

*J. Neason*  
24/5/37  
© 2019  
Lloyd's Register  
Foundation